



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

May 23, 2008

WISCONSIN HOMES, INC.
ENGINEERING DEPARTMENT
CHUCK BUBOLZ
PO BOX 0250
MARSHFIELD WI 54449-0250

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: WISCONSIN HOMES, INC.
Product Name: PREFABRICATED PLUMBING SYSTEM
Model Number(s): #1P AND #1PF
Product File No: 20080271

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2012.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 15 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.
- The maximum water supply fixture units (wsfu) on Type L copper tubing must not exceed 31.0 wsfu for 1-inch tubing, 16.5 wsfu for 3/4-inch tubing and 6.5 wsfu for 1/2-inch tubing.
- Installation of Oatey Sure-Vent II air admittance valves are optional for venting sinks, tubs, showers and lavatories in accordance with the Oatey Sure-Vent II Wisconsin product approval.

This approval supersedes the approval issued on December 14 2007 under product file number 20070478.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070478.

A copy of the approved plans and/or specifications is enclosed. The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov